

E-Stop Safety Modules with Adjustable Delay

Models **ES-TN-14H5** with 0-20 second delay, **ES-TN-14H6** with 0-200 second delay



Features

- · Selectable Auto-Reset or monitored Manual Reset.
- · Auto or manual power-up
- One- or two-channel feedback monitoring
- Monitors one dual-channel or one single-channel normally closed E-stop switch circuit for a contact failure or wiring fault (safety category 2 or 4. per ISO13849-1 [EN954-1]; see pages 5-7).
- 4 amp safety output contacts
- · Removable terminal blocks
- · Input monitoring circuit has diverse-redundant microprocessors
- Designed for use in functional stop Category 0 and 1 applications (per ISO/EN 60204-1 and NFPA79)
- Four immediate output switching channels (functional stop Category 0) and four delayed output switching channels (functional stop Category 1). Delay time is adjustable from 0-20 seconds or 0-200 seconds, depending on model.
- One auxiliary non-safety, normally closed immediate output and one auxiliary non-safety normally closed delayed output for status monitoring.



WARNING . . . This Emergency Stop Safety Module is not a point-of-operation quarding device, as defined by OSHA regulations. It

is necessary to install point-ofoperation quarding devices, such as safety light screens and/or hard guards, to protect personnel from hazardous machinery. Failure to install point-of-operation quards on hazardous machinery can result in a dangerous condition which could lead to serious injury or death.



Important ... read this page before proceeding!

Banner Engineering Corp. has made every effort to provide complete application, installation, operation, and maintenance instructions. In addition, any questions regarding the use or installation of this Banner Emergency Stop Safety Module should be directed to the factory applications department at the telephone numbers or address shown on back cover.

The user shall ensure that all machine operators, maintenance personnel, electricians, and supervisors are thoroughly familiar with and understand all instructions regarding the installation, maintenance, and use of this Emergency Stop Safety Module, and with the machinery it controls.

The user and any personnel involved with the installation and use of this model Emergency Stop Safety Module must be thoroughly familiar with all applicable ANSI/NFPA standards. The standards, listed below, directly address the use of emergency stop systems. Banner Engineering Corp. makes no claim regarding a specific recommendation of any organization, the accuracy or effectiveness of any information provided, or the appropriateness of the provided information for a specific application.

The user has the responsibility to ensure that all local, state, and national laws, rules, codes, and regulations relating to the use of this Emergency Stop Safety Module in any particular application are satisfied. Extreme care is urged that all legal requirements have been met and that all installation and maintenance instructions contained in this manual are followed.

U. S. Standards Applicable to Use of Emergency Stop Safety Modules

ANSI B11 Standards for Machine Tools "Safety Requirements for the Construction, Care and Use"

Available from: Safety Director

AMT – The Association for Manufacturing Technology

7901 Westpark Drive McLean, VA 22101-4269 Tel.: 703-893-2900

NFPA79 "Electrical Standard for Industrial Machinery (1997)"

Available from: National Fire Protection Association

1 Batterymarch Park, P.O. Box 9101

Quincy, MA 02269-9101 Tel.: 800-344-3555

ANSI/RIA R15.06 "Safety Requirements for Industrial Robots and Robot Systems"

Available from: Robotic Industries Association

900 Victors Way, P.O. Box 3724

Ann Arbor, MI 48106 Tel.: 734-994-6088

European Standards Applicable to Use of Emergency Stop Safety Modules

ISO/TR 12100-1 & -2 (EN292-1 & -2) "Safety of Machinery – Basic Concepts, General Principles for Design

Part 1: Basic Terminology, Methodology, and Part 2: Technical Principals and Specifications"

ISO 13849-1 (EN954-1) "Safety of Machines: Safety Related Parts of Control Systems" IEC/EN60204-1 "Electrical Equipment of Machines: Part 1: General Requirements"

Also, request a type "C" standard for your specific machinery.

ISO 13850 (EN418) "Safety of Machinery – Emergency Stop Equipment Functional Aspects, Principles for Design"

Available from: Global Engineering Documents

15 Inverness Way East Englewood, CO 80112-5704

Tel.: 800-854-7179

Key to Categories

 A Functional Stop Category (0, 1 or 2), per EN60204-1 and NFPA79, refers to the type of stopping action required by the guarded machine in guestion. Some machines may be stopped safely, immediately following a stop command (removal of power); others, due to their high speed, mass or momentum, would run on following an immediate stop command. These machines require power to be provided to the guarded machine's braking system for a specified delay time, to effect a controlled stop.

Category 0 Stop: immediate removal of power, uncontrolled stop

Category 1 Stop: controlled stop with a delay before power is removed from guarded machine

Category 2 Stop: controlled stop with power left available to the guarded machine actuators

- A Safety Category (B, 1, 2, 3 or 4), per EN954-1, refers to "the performance of a safety related part of a control system (or circuit) with respect to the occurrence of faults..." Of the many factors involved when selecting an appropriate safety category, hazard analysis, risk assessment and risk reduction are among the most important. The level of risk is based on the severity of a potential harm and its probability of occurring, which is used to determine the appropriate performance of a control system or circuit. Typically, as described in Annex B of EN954-1, in cases where serious injury is possible:
 - Safety Category 2 would be selected only if exposure to a hazard is infrequent, and of a short duration.
 - Safety Category 4 would be selected if exposure to a hazard is frequent to continuous, or if exposure is for a long duration.

For more information, refer to standards EN954-1, EN418, NFPA 79, EN60204-1 and British Standard 5304:(1988).

Overview

The purpose of an Emergency Stop Safety Module (E-Stop Safety Module) is to increase the control reliability of an emergency stop circuit. As indicated in Figures 2 and 3, the E-Stop Safety Modules described in this document are designed to monitor a 1-channel or 2-channel E-stop switch. A 2-channel E-stop switch has two electrically isolated contacts.

ISO 13849-1 Safety Categories

Both contacts of a 2-channel E-stop switch are monitored by the Safety Module. If either input is short-circuited, the Safety Module cannot be reset, and the controlled machinery cannot be restarted, following actuation of the E-stop switch. Two-channel E-stop switches used with this Safety Module are suitable for Safety Category 4 applications, per European Standard ISO 13849-1 (EN954-1), of which Category 4 is the highest safety category.

Use of a 1-channel E-stop switch provides no input redundancy, and no ability for the Safety Module to monitor for input short circuits. One-channel E-stop switches used with this Safety Module are generally suitable only for Safety Category 2 applications, per ISO 13849-1 (EN954-1).

IEC/EN60204-1 and NFPA79 Functional Stop Categories

In a functional Category 0 emergency stop circuit, the opening of either of the two E-stop switch contacts (or the one contact, if configured to 1-channel) immediately removes electrical power from the machine control elements, which react to stop hazardous machine motion and/or other machine hazards. This redundancy of stopping control offered by a two-pole E-stop switch is the first step towards control reliability in an emergency stop circuit.

A functional stop Category 1 emergency stop circuit is a controlled stop with power available to the machine actuators to achieve the stop and then removal of power when the stop is achieved. When a Category 1 stop function is used, final removal of power must be ensured by means of electromechanical switching devices.

Functional stop Category 1 stops are intended for use on machines where immediate removal of power would not stop the machine immediately because its high speed. high mass or momentum would cause the machine to run on. To stop such machines quickly and safely, electro-mechanical or electrical brake systems like DC-injection brakes or reverse current via the machine's actuators are commonly used.

The outputs of E-stop Safety Modules ES-TN-1H5 and -1H6 are two redundant normally open immediate safety contacts (each of which is a series of two forcedguided relay contacts, K1 and K2 in Figure 3), and two redundant normally open delayed contacts (also each a series of two forced-guided relay contacts, K3 and K4). The delayed contacts may be used in a functional stop Category 1 application.

In addition to the safety contacts, the E-Stop Safety Module has one normally closed immediate auxiliary contact (from K1 and K2) and one normally closed delayed auxiliary contact (from K3 and K4) for status monitoring by a process controller.

All output contacts of the E-Stop Safety Module, the normally open and the normally closed, are rated for up to 250V ac/dc at up to 4 amps.

The E-Stop Safety Module also provides a necessary reset function. ANSI B11 and NFPA 79 standards require that a Reset routine be performed after returning the E-stop switch to its closed-contact position. This prevents the controlled machinery from restarting simply by closing the E-stop switch. Models ES-TN-14H5 and -14H6 may be configured for Automatic Reset via two DIP switches located inside the Module housing, under the front cover (see Figures 5 and 6). Automatic Reset mode is useful for some automated processes. However, when Automatic Reset is used, an alternate means must be established to require a Reset routine after the E-stop switch is returned to its closed-contact position (see WARNING on page 9).

This E-Stop Safety Module complies with the following design standards:

ISO 13850	Emergency Stop Equipment – Functional Aspects,
-----------	--

Principles for Design

ISO 13849-1 Safety of Machinery: Safety-related Parts of Control Systems

Part 1: General Design Directives (Safety Category 4)

ISO 12100-2 Safety of Machinery: Basic Concepts, General Principles for Design

(EN292-2) Part 2: Technical Principles and Specifications

IEC 60204-1 Safety of Machinery: Electrical Equipment of Machines

Part 1: General Requirements

The Safety Module has indicators for input power (Power), internal faults (Fault), Estop inputs (E-Stop), reset input (Reset), monitoring of feedback contacts (Monitor), immediate outputs (Out) and delayed outputs (Timed-Out); see Figure 1.

E-Stop Safety Modules ES-TN-14H5 and -14H6 have no user-serviceable parts. See page 16 for information regarding repair service.




Figure 1. ES-TN-14H5 and -14H6 status indicators and terminal locations

E-Stop Switch Requirements

As shown in Figure 3, the E-stop switch must provide one or two contacts which are closed when the switch is armed. Once activated, the E-stop switch must open all its contacts, and must be returned to the closed contact position only by means of a deliberate action (such as twisting, pulling, or unlocking). The switch should be a "positive-opening type," as described by IEC 60947-5-1. A mechanical force applied to such a button (or switch) is transmitted directly to the contacts, forcing them open. This ensures that the switch contacts will open whenever the switch is activated. NFPA 79 section 13.2, Emergency Stop Devices, specifies the following additional switch ("stop control") requirements:

- Emergency Stop push buttons shall be located at each operator control station and at other operating stations where emergency shutdown shall be required.
- Stop and Emergency Stop push buttons shall be continuously operable from all control and operating stations where located.
- Actuators of Emergency Stop devices shall be colored RED. The background immediately around the device actuator shall be colored YELLOW. The actuator of a push-button-operated device shall be of the palm or mushroom-head type.
- The Emergency Stop actuator shall be a self-latching type.

NOTE: Some applications may have additional requirements. The user must refer to all relevant regulations.

If the Module is configured for 1-channel E-stop (S11-S12), a jumper must be installed on the second channel (S21-S22) and configured for 1-channel input; see Figure 6.

When a 1-channel E-stop is used, the user must guard against failure modes that can result in an unsafe condition, for example the failure of the contact to a short circuit condition. A switch with positive opening operation should be used to reduce the possibility of a failure of the switch to open. A short circuit failure results in loss of switching function. This can occur from a short across the switch contacts, a short across the wires connected to the switch somewhere between the switch and the E-Stop Safety Module, or a short to a secondary source of power. To reduce these possibilities, physically separate the wires from each other and from other sources of power (e.g., in separate wireways or conduit).

According to the definition of European standard ISO 13849-1 (EN954-1), a 1-channel E-stop generally should be used only in an application where Safety Category 2 or less (1 or B) has been determined via a risk-assessment procedure.

Two-channel E-stops, with positive open switches, are designed to issue a stop command even in the event of a single failure of this type and provide a high level of

If the Module is configured for 2-channel E-stop, the immediate normally open output contacts (13-14, 23-24, 33-34 and 43-44), will open and the normally closed auxiliary contact (91-92) will close as soon as at least one of the two E-stop contacts opens. The second contact, however, must open within 2 seconds of the first one; if not, the unit will go into a lockout condition that results in the outputs opening and requiring a reset after the fault has been corrected.



WARNING . . . 1-Channel Input

If a 1-channel E-stop button is used, a single fault (such as a short across the single E-stop contact or from the contact to a secondary source of power) can lead to the complete loss of safety.

A 1-channel E-stop should be used only in applications where such a fault can be excluded, or the resulting loss of safety cannot result in serious injury or death (Safety Category 2. 1 or B: see page 3).

If a 1-channel E-stop is used, separate the wires from each other by routing them through separate wireways or conduit in order to increase the reliability of the interface.

Mechanical Installation

The E-Stop Safety Module must be installed inside an enclosure. It is not designed for exposed wiring. It is the user's responsibility to house the E-Stop Safety Module in an enclosure with NEMA 3 or IEC IP54 rating, or better.

Dimensions of the Safety Module are shown in Figure 8, page 16. The Safety Module mounts directly to standard 35 mm DIN rail.

Heat Dissipation Considerations

For reliable operation, the user must ensure that the operating specifications are not exceeded. The enclosure must provide adequate heat dissipation, so that the air closely surrounding the Module does not exceed the maximum operating temperature stated in the specifications (page 15). Methods to reduce heat build-up include venting, forced airflow (e.g., exhaust fans), adequate enclosure exterior surface area and spacing between modules and other sources of heat.

Electrical Installation

It is not possible to give exact wiring instructions for a device such as an E-stop Safety Module which interfaces to a multitude of machine control configurations. The following guidelines are general in nature.

Models ES-TN-14H5 and -14H6 have four redundant *immediate* normally open supply output contacts (13-14, 23-24, 33-34 and 43-44), as well as four redundant *delayed* contacts (57-58, 67-68, 77-78 and 87-88). This qualifies this E-Stop Module to be used in applications as a functional stop Category 0 or 1 E-Stop Control as defined by NFPA 79 and ISO 13850 (EN418).

NOTE: As the normally open immediate and delayed output contacts come from physically separate relays, a fault could cause only one set of contacts (either the immediate or the delayed) to close after a manual or auto reset. This possibility must be considered in the design of the machine control circuit.

Connection of E-Stop Switch

Connect the poles of the E-Stop switch as shown in Figure 3. The switch in Figure 3 is shown in the "armed" position with both contacts closed. Multiple E-stop switches connected to one E-stop Safety Module must be series connected (see Figure 2 and the warning at right).



CAUTION. . . Shock Hazard Always disconnect power from the E-stop Safety

Module and all power from the machine being controlled before making any wire connections.

Electrical installation and wiring must be made by qualified personnel and must comply with the NEC (National Electrical Code), EN60204-1 and -2, and all applicable local standards and codes.




Figure 2. Series connection of multiple E-Stop switches. Jumper between S21 and S22, if 1-channel E-stop is selected.



Whenever two or more E-stop switches are connected to the same E-Stop Safety Module:

- The contacts of both switches must be connected together in series. This series combination is then wired to the respective Safety Module input. Never connect the contacts of multiple Estop switches in parallel to the E-Stop Safety Module inputs; this defeats the switch contact monitoring ability of the Safety Module, and creates an unsafe condition.
- Each switch must be individually actuated (engaged), then re-armed and the E-Stop Safety Module reset (if Manual Reset mode is selected). This allows the monitoring circuits to check each switch and its wiring to detect faults.

Failure to do so could result in undetected faults and create an unsafe condition which could result in serious injury or death.




Figure 3. E-Stop Safety Modules ES-TN-14H5 and -14H6 hookups

Connection of Safety Switches

Models ES-TN-14H5 and ES-TN-14H6 may be used as a safety gate monitoring module. To achieve Safety Category 4 operation per ISO 13849-1, two individually mounted, positive-opening safety switches that operate concurrently when the gate or guard is opened must be used (see Figure 4).

The ES-TN-14H5 and ES-TN-14H6 verify concurrent opening of two contacts – one from each safety switch. Reset of the Safety Module is not possible if one switch fails to open, or if a short circuit occurs between the safety switches or to dc common or to +24V.

Please contact the Banner Factory Applications Group at the numbers listed on the last page to discuss your intended use.

Connection of Reset Switch (Manual Monitored Reset)

The Reset Circuit switch can be any mechanical switch, such as a normally open momentary switch, or a two-position key switch. The Reset switch must be capable of reliably switching 18-30V dc at 10-25 mA. As shown in Figure 2, the Reset switch connects between terminals X1 and X2 of the Safety Module. A reset will occur after the Reset button goes from open, to closed, and back to open state.

The Reset switch must be located outside of – and not be accessible from – the area of dangerous motion, and must be positioned so that any area of dangerous motion may be observed by the switch operator during the Reset procedure.

External Device Monitoring (EDM)

To satisfy the requirements of Safety Category 4 of ISO 13849-1, the Master Stop Control (MSC) elements must each offer a normally closed, forced-guided monitor contact. For **2-channel monitoring**, one normally closed monitor contact from one MSC element, controlled by one of the immediate output contacts from the Module, is wired in series to one normally closed monitor contact from one MSC element, controlled by one of the delayed output contacts from the Module, to input X3-X4. The same configuration (one immediate N.C. series connected to one delayed N.C.) is wired to X5-X6 (Figure 2). In operation, if one of the switching contacts of any MSC element fails in the shorted condition, the associated monitor contact will remain open, making reset of the Module impossible.

There is no specific feedback input to which the immediate MSCs must be connected. However, two immediate contacts (from two MSCs) or two delayed contacts (from two MSCs) should not be connected to the same input. If **1-Channel Monitoring** is selected, input X5-X6 must be jumpered, the Module configured for 1-Channel Monitoring (see Figure 2) and all monitoring contacts must be wired in series to X3 and X4. See 1-Channel, 2-Channel, or No External Device Monitoring on page 10 for more information.

Connection to the Guarded Machine

The hookup diagram (Figure 2) shows a generic connection of 4 of the E-Stop Safety Module's eight redundant output circuits to Master Stop Control elements MSC1 through MSC4. A Master Stop Control element is defined as an electrically powered device, external to the E-Stop Safety Module, which stops the machinery being controlled by immediately removing electrical power to the machine and (when necessary) by applying braking to dangerous motion. This stopping action is accomplished by removing power to the actuator coil of any Master Stop Control Element.




Figure 4. Hookup using contacts from two safety switches

Configuration

Automatic Reset Mode

The E-Stop Safety Module may be configured for Automatic Reset via two independent DIP switches, located inside the Module housing, under the front cover (see Figures 5 and 6) and by replacing the Reset switch with a jumper wire in the X1-X2 reset input circuit (see Figure 2).

The E-Stop Safety Module will reset (and the outputs energize) as soon as the E-Stop switch returns to its closed-contact position (S11-S12 and S21-S22 closed), feedback inputs are closed (X3-X4 and X5-X6), and no fault exists. Automatic Reset will not occur if Manual Power-up is selected and the E-stop switch is already closed when power is applied.

Automatic reset mode is useful for some automated processes. **However, if Automatic Reset is used, it is necessary to provide a means of preventing resumption of hazardous machine motion, until an alternate reset procedure is performed.** The alternate procedure must include a Reset switch, located outside the area of dangerous motion, which is positioned so that any area of dangerous motion may be observed by the switch operator during the reset procedure.

NOTE: The minimum amount of time required for the Module to be in a STOP or OFF condition is 100 ms. This "recovery time" (OFF-state) is required for the internal circuitry of the Safety Module to normalize, allowing a reliable reset to occur. A lockout will occur if the Module is cycled too quickly. To clear the lockout, the Module must be re-cycled, meeting the minimum OFF time requirement.

WARNING . . . Reset Routine Required

ANSI B11 and NFPA 79 standards require that a reset routine be performed after returning the E-stop switch to its closed-contact position (arming the E-stop switch). When Automatic Reset is used, an alternate means must be established to require a reset routine, after the E-stop switch is armed. Allowing the machine to restart as soon as the E-stop switch is armed creates an unsafe condition which could result in serious injury or death.

WARNING . . . Auto Power-Up and Momentary Power Loss

If Auto Power-Up is selected, a momentary loss of power could cause the outputs to energize, even without a manual reset, when the power resumes. Be sure that this Auto Power-Up situation does not cause the machine to restart, or an unsafe condition may occur that could result in serious injury or death.

Auto Power-Up

If the Module is programmed for Auto Power-Up (see Figures 6 and 7), K1-K4 relays will close as soon as power is connected to A1-A2 – if the E-stop inputs S11-S12 and S21-S22 are closed, the appropriate jumpers are installed and feedback contacts X3-X4 and X5-X6 are closed, whether the Module is programmed for Auto or Manual Reset.

Auto Reset may be used only if the machine being controlled will not initiate dangerous motion if power is applied to or interrupted from the module. In addition, an alternate Reset routine must be required (see WARNING at left).

The next time the E-stop is cycled when the Module is set to Manual Reset, the Reset button at X1-X2 must go from open to closed and back to open in order to reset the unit and energize the four internal relays.

NOTE: Auto Power-Up in combination with Manual Reset energizes the output contacts automatically only one time after applying power to the Module. Cycling the E-stop button while power is applied *will not reset the unit*.

Manual Power-Up

If the DIP switches are set to Manual Power-Up and Manual Reset, the unit will reset only after power is applied and the Reset button is pushed and released. If Manual Power-Up and Auto Reset is selected, the E-stop button must be cycled (opened and closed) if it is closed after power up (but simply closed if it is open after power-up).

Cancel Delay Input

The Cancel Delay Time input Y1-Y2 must be open during normal operation. After the E-stop button is activated (its contacts opened), and the delay time is running, a momentary closing of input Y1-Y2 will immediately terminate the delay time and open contacts 57-58, 67-68, 77-78 and 87-88, and close contact 01-02. A jumper between Y1-Y2 results in a Fault condition.

External Device Monitoring Settings

1-Channel Monitoring

If 1-channel monitoring is selected (see Figure 6), one or more normally closed contacts from the MSCs must be wired to terminals X3-X4. If more than one contact is used, they must be wired in series (see Figure 3). The second channel (X5-X6) must be jumpered. The Module will reset only if both inputs are closed. After the unit is reset, the state of the X3-X4 input is irrelevant.

2-Channel Monitoring

If 2-channel monitoring is selected (see Figure 6), the Module will check both inputs X3-X4 and X5-X6 for closed state, before a reset can occur. After the unit is reset, and during RUN mode, both inputs will be checked for matching state. In other words, if one input opens, the other input must open within 200 milliseconds.

If both pairs of output contacts (both immediate and delayed) are used, and MSCs from all four contacts are controlled (Figure 3), both an immediate MSC and a delayed MSC contact must be connected in series to each of the two feedback inputs.

No External Device Monitoring

If monitoring contacts are not required or if External Device Monitoring is not otherwise possible, jumper both X3-X4 and X5-X6 inputs and select 2-channel monitoring. It is the responsibility of the user to ensure that any single failure will not result in a hazardous condition and will prevent a successive machine cycle.



CAUTION . . . Turn OFF Power Before Removing Cover

The front cover should only be removed and the switches set when no voltage is applied to terminals A1-A2. Changing the position of the switches while power is ON could result in a Fault condition or a short circuit.




Figure 5. Use a screwdriver to gently pry the cover loose from the Module housing.




Figure 6. Module DIP switches and selectors, set to factory settings

DIP-Switch and Selector Switch Settings

The DIP switches and selector switches are located inside the Module housing, behind the front plate. Before adjusting any settings, turn OFF power to the Module. Remove the front plate by using a screwdriver in the slot on the right side and gently prying the cover away from the housing (Figure 5). Turn the rotary Delay Time selector switches to the desired position using the same small screwdriver in the slot on the arrow. Use the screwdriver blade to slide the DIP switches to their proper positions also.

The corresponding pairs of DIP switches and the two rotary Delay Time selector switches must match at all times, or a Fault condition will result. (If this occurs, turn the power OFF, adjust the pairs of switches to match, and turn the power supply back ON.) Figure 6 shows the DIP switches and Delay Time selector switches properly set for No Delay, Manual Reset, 1-Channel Monitoring, Manual Power-Up, and 2-Channel Input.

The E-Stop Safety Module factory settings are as follows:

Switch	Factory Setting	Optional Setting		
Manual/Auto Reset (S1, S1.1)	0 – Manual reset	1 – Auto reset		
1-/2-Channel Monitoring (S2, S2.1)	0 – 1-Channel Monitoring	1 – 2-Channel Monitoring		
Manual/Auto Power-Up (\$3,\$3.1)	0 – Manual power-up	1 – Auto power-up		
2-/1-Channel E-Stop (S4, S4.1)	0 – 2-Channel E-stop	1 – 1-Channel E-stop		
Delay Time Seconds* (T1, T2)	0 – 0 Seconds	See table below		

^{*}The amount of delay time between the opening of contacts 13-14, 23-24, 33-34 and 43-44, and contacts 57-58, 67-68, 77-78, and 87-88.

Optional settings for Delay Time (T1/T2) rotary switches (in seconds):

	Switch Position	0	1	2	3	4	5	6	7	8	9	
	ES-TN-1H5	0	0.5	1	2	4	6	8	10	15	20	Seconds
ĺ	ES-TN-1H6	0	5	10	20	30	50	70	100	150	200	Seconds



WARNING . . . Consequence of OFF-Delay Failure

It is possible for any programmed OFF-delay timing function to fail, due to circuit failure or power loss, resulting in premature opening of the delay contacts. The installation, including its wiring, must be designed to prevent any hazard which could result from the loss of a programmed output switching delay time.



WARNING . . . After Switch Configuration

Follow the complete checkout and

troubleshooting procedure (see page 12) following any change in the settings to the DIP switches or Time Delay Selector Switches.

Initial Checkout and Troubleshooting Procedure

NOTE: If more than one E-Stop switch is series-connected to one E-Stop Safety Module, this checkout procedure must be run individually for each switch.

- 1. Remove power from the machine being guarded and from the E-Stop Safety Module.
- 2. Activate the E-stop buttons (open their contacts).
- 3. Remove the E-Stop Safety Module front cover, (see Figure 5).
- 4. Check for correct settings on the DIP switches S1-S4 and S1.1-S4.1 (see Figure 6). The related pairs of switches (S1/S1.1, S2/S2.1, S3/S3.1, and S4/S4.1) must match at all times, as must the two Delay Time selector switches (T1/T2).
- 5. After switches are set to the proper position for the application, replace the E-Stop Safety Module front cover.
- 6. Make sure that jumpers, if required, are installed:

1-channel monitoring: X5-X6 **1-channel E-stop:** S21-S22 **No monitoring:** X3-X4, X5-X6 **Auto reset:** X1-X2

- 7. Turn the power ON to the E-Stop Safety Module. All LEDs will turn ON for a period of about 0.5 seconds, after which time all but the power LED will turn OFF for about 0.5 seconds; then the normal status indicator function will be displayed. If any LEDs do not cycle ON, then OFF after power is ON, disconnect power and check all wiring; return to step 5 after correcting the problem. If the problem cannot be corrected, return the Module to the factory for repair (see step 12 and page 16).
- E-Stop LED will be OFF if the E-stop contacts are not closed. Out and Timed-Out LEDs must be OFF; Monitor LED must be ON (monitor inputs are closed). The Reset LED must be OFF if configured for Manual Reset, and ON if configured for Automatic Reset.
- 9. Arm the E-stop button.
 - If the Module is set for Auto Reset, output contacts 13-14, 23-24, 33-34, 43-44, 57-58, 67-68, 77-78, and 87-88 should close immediately, and contacts 91-92 and 01-02 should open immediately. E-Stop, Out, and Timed-Out LEDs must all come ON.

 If the Module is set for Manual Reset, the E-Stop LED will come ON.

 After the E-Stop button is armed and the Reset LED starts flashing, reset the Module by closing and opening the reset input. (The Reset button should remain closed longer than 100 ms, but not longer than 2.5 seconds. The Reset LED will begin to flash again if the button is held in too long.) After Reset is opened, the Out and Timed-Out LEDs must come ON immediately. All normally open output contacts are closed now, and all normally closed output contacts are open. The Reset LED will be steady ON as long as the reset input is closed; it will go OFF if the reset input is opened and the four relays are ON.
- 10. Activate the E-Stop switch (open its contacts); the E-Stop LED must go OFF. Out LED must go OFF. Contacts 13-14, 23-24, 33-34, 43-44, 57-58, 67-68, 77-78, and 87-88 must open immediately; contacts 91-92 and 01-02 will close immediately. Contacts 57-58, 67-68, 77-78, and 87-88 open after the selected delay time; contact 01-02 closes after the selected delay time. Timed-Out LED will go OFF after the delay time is over.
- 11. (Optional) Close the Cancel Delay input to immediately terminate the delay.
- 12. If the complete Safety Module must be replaced, the modular terminal strips may easily be removed for quick installation into another module. To remove the terminal strips, first replace the Safety Module front cover. Then insert the blade of a small screwdriver into one of the four depressions in the Safety Module front cover and pry them loose; see Figure 7.



Figure 7. To remove the Module's terminal strips, insert a small screwdriver blade into each of the four slots at the top and bottom of the front cover.



CAUTION . . . Disconnect Power Prior to Checkout

Before performing the initial checkout procedure, make certain all power is disconnected from the machine to be controlled.

Dangerous voltages may be present along the E-stop Safety Module wiring barriers whenever power to the machine control elements is ON. Exercise extreme caution whenever machine control power is or may be present. Always disconnect power to the machine control elements before

opening the enclosure housing of the

E-stop Safety Module.

Periodic Checkout Procedure

The functioning of the E-stop system must be verified periodically to ensure proper operation (see also the machine manufacturer's recommendations).

NOTE: If two or more E-stop switches are series-connected to one E-Stop Safety Module, this test must be individually run for EACH switch.

Procedure:

- 1. With the machine running, engage the E-stop switch (open its contact). Verify that the machine stops.
- 2. Return the E-stop switch to its closed-contact position. Verify that the machine does not restart.
- 3. Close and then open the Reset switch (if using manual reset mode). Verify that the machine can restart.

LED Indicators

E-Stop Safety	y Modules ES-TN-14H5 and -14H6 provide seven indicator LEDs
Power (green)	ON – Power is connected to terminals A1-A2 OFF – No power or low power to terminals A1-A2, or internal power supply failure
Fault (red)	ON – External fault or configuration fault. The corresponding function LED (see below) will flash to indicate the area where the fault has been detected. See Fault Indication Table for probable cause. Flashing – Internal Fault. See page 16 for repair.
E-Stop (green)	ON – E-Stop inputs are closed (S11-S12 and S21-S22). OFF – E-Stop inputs are open. Flashing (Fault LED OFF) – If the module is configured for Manual Power-up and Auto Reset, the E-Stop button must be cycled (opened, then closed) to enter RUN mode. (Ensure Cancel Delay input is open or a fault will occur.) Flashing (Fault LED ON) – See Fault Indication Table for probable cause.
Reset (green)	ON – Reset input is closed (X1-X2). OFF – Reset input is open. Flashing (Fault LED OFF) – "Reset Requested." The Reset input (button) must be cycled (closed, then opened), to enter RUN mode. Flashing (Fault LED ON) – See Fault Indication Table for probable cause.
Monitor (green)	ON – Monitoring inputs are closed (X3-X4 and X5-X6). OFF – Monitoring inputs are open. Flashing (Fault LED ON) – See Fault Indication Table for probable cause.
Out (green)	ON – Both internal relays K1 and K2 are energized. (Immediate N.O. outputs 13-14, 23-24, 33-34 and 43-44 are closed. Immediate N.C. output 91-92 is open.) OFF – Both internal relays K1 and K2 are de-energized. (Immediate N.O. outputs 13-14, 23-24, 33-34 and 43-44 are open. Immediate N.C. output 91-92 is closed.)
Timed-out (green)	ON – Both internal relays K3 and K4 are energized. (Delayed N.O. outputs 57-58, 67-68, 77-78 and 87-88 are closed. Delayed N.C. output 01-02 is open.) OFF – Both internal relays K3 and K4 are de-energized. (Delayed N.O. outputs 57-58, 67-68, 77-78 and 87-88 are open. Delayed N.C. output 01-02 is closed.) Flashing (Fault LED ON) – See Fault Indication Table for probable cause.

Clearing Faults

To clear a fault condition, first correct the problem and then cycle the E-stop inputs to the module. When the Fault LED lights, the corresponding Function LED will flash to indicate the problem. If the Fault LED is flashing, refer to "Repairs," on page 16.

LED	Indication	Fault and Probable Cause
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON ON FLASHING OFF ON or OFF OFF	E-Stop Input Fault a) Jumper on S21-S22 missing if configured for 1-Channel E-Stop (S4/S4.1 = 1). b) Simultaneity fault on opening of E-Stop input channels (S11-S12 and S21-S22 must open within 2 seconds of each other). c) Short circuit between channels. d) E-Stop input short circuit to power or common.
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON ON ON or OFF FLASHING ON or OFF OFF OFF	Reset Input Fault a) Jumper on X1-X2 missing if configured for Auto Reset (S1/S1.1 = 1). b) Reset input short circuit to power or common. c) X1-X2 jumpered when configured for Manual Reset (S1/S1.1 = 0).
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON ON ON or OFF ON or OFF FLASHING OFF OFF	 Monitoring Input Fault a) One or both monitoring inputs are open during reset. b) In 2-Channel Monitoring, inputs are not in the same state within 200 milliseconds of each other after the N.O. outputs close. c) In 1-Channel Monitoring, the X3-X4 input was not closed during reset. d) In 1-Channel Monitoring, the jumper on X5-X6 is missing.
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON FLASHING ON OR OFF ON OR OFF ON OR OFF OFF	Internal Fault a) Internal relay failure. b) Incorrect check sum. c) Other internal fault.
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON ON ON or OFF ON or OFF ON or OFF OFF	Configuration Fault a) DIP switch blanks do not match. b) DIP switches changed while powered up. c) Time-delay rotary switches do not match. d) Time-delay rotary switches changed while powered up. Cycle the power OFF, then ON to clear the fault.
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON ON FLASHING ON ON OFF OFF FLASHING	E-Stop Release Fault a) In Auto-Reset, the E-Stop button was re-armed (closed) before timed-out (K3-K4 de-energized).
POWER FAULT E-STOP RESET MONITOR OUT TIMED-OUT	ON ON ON ON or OFF ON or OFF OFF FLASHING	 Cancel Delay Input Fault a) In Auto Reset mode, the E-Stop button was re-armed (closed) with cancel delay input closed. b) In Manual Reset mode, the E-Stop button was re-armed (closed) and the reset button pushed and released with cancel delay input closed.

Specifications					
Supply Voltage and Current	24V dc, ±20% Power consumption: approx. 5 W				
Supply Protection Circuitry	Protected against transient voltages and reverse polarity				
Output Configuration	Outputs K1 & K2: four redundant (total of eight) safety relay (forced-guided) contacts — AgNi, gold flashed one auxiliary N.C. contact — AgNi, gold flashed Outputs K3 & K4: four redundant (total of eight) delayed relay (forced-guided) contacts — AgNi, gold flashed one auxiliary N.C. contact — AgNi, gold flashed Contact ratings (all normally open and normally closed output contacts): Max. voltage: 250V ac or dc Max. current: 4 A ac or dc Min. current: 30 mA @ 24V dc Max. power: 1000VA, 100W Mechanical life: 50,000,000 operations Electrical life: 100,000 at full resistive load NOTE: Transient suppression is recommended when switching inductive loads. Install suppressors across load. Never install suppressors across output contacts (see Warning, page 6).				
Output Response Time	K1 & K2: 50 milliseconds typical K3 & K4 (ES-TN-14H5): 0, 0.5, 1, 2, 4, 6, 8, 10, 15, 20 seconds K3 & K4 (ES-TN-14H6): 0, 5, 10, 20, 30, 50, 70, 100, 150, 200 seconds Delayed Output Timing Tolerance: Set time ±100 ms or ±2%, whichever is greater				
ON-Time Delay	≥ 100 ms; Time from the E-stop contacts to close (Auto Reset) or the Reset button to open (Manual Reset) and the safety outputs to close				
Input Requirements	E-stop switch must have a normally closed contact capable of switching 20 mA @ 24V dc. Reset switch must have one normally open contact capable of switching 20 mA @ 24V dc. NOTE: Inputs must be voltage-free, dry contacts.				
Status Indicators	6 green LED indicators: Power Monitor Fault E-Stop Out (K1 & K2 ON/OFF) Reset Timed-Out (K3 & K4 ON/OFF)				
Housing	Polycarbonate. Rated NEMA 1; IEC IP40, Terminals IP20, max. terminal torque 0.8 Nm				
Mounting	Mounts to standard 35 mm DIN rail track. Safety Module must be installed inside an enclosure rated NEMA 3 or IEC IP54, or better.				
Vibration Resistance	10 to 55Hz @ 0.35 mm displacement per IEC 68-2-6				
Operating Conditions	Temperature: 0° to +50°C (+32° to 122°F) Maximum Relative Humidity: 90% @ +50°C (non-condensing) Heat Dissipation Considerations: See page 7.				
Dimensions	See Figure 8.				




Figure 8. E-Stop Safety Modules ES-TN-14H5 and ES-TN-14H6 enclosure dimensions

Repairs

NOTE: Do not attempt any repairs to the ES-TN-14H5 or -14H6 Emergency Stop Safety Module. They contain no field-replaceable components. Return the Safety Module to the factory for warranty repair or replacement.

If it ever becomes necessary to return an E-Stop Safety Module to the factory, please do the following:

- Contact the Banner Factory Application Engineering Group at the address or at the numbers listed below. They will attempt to troubleshoot the system from your description of the problem. If they conclude that a component is defective, they will issue an RMA (Return Merchandise Authorization) number for your paperwork, and give you the proper shipping address.
- 2) Pack the E-Stop Safety Module carefully. Damage which occurs in return shipping is not covered by warranty.



WARNING . . . Abuse of Module After Failure

If an internal fault has occurred and the Module will not reset, do not tap, strike, or otherwise attempt to correct the fault by a physical impact to the housing. An internal relay may have failed in such a manner that its replacement is required.

If the Module is not immediately replaced or repaired, multiple simultaneous failures may accumulate such that the safety function can not be guaranteed.



WARRANTY: Banner Engineering Corp. warrants its products to be free from defects for one year. Banner Engineering Corp. will repair or replace, free of charge, any product of its manufacture found to be defective at the time it is returned to the factory during the warranty period. This warranty does not cover damage or liability for the improper application of Banner products. This warranty is in lieu of any other warranty either expressed or implied.

P/N 68436 rev. A