


BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P



- On-machine Compact fieldbus I/O block
- EtherNet/IP™, Modbus® TCP, or PROFINET slave
- Integrated Ethernet Switch
- 10 Mbps / 100 Mbps supported
- Two 4-pole M12, D-coded, connectors for fieldbus connection
- 2 rotary switches for node address
- IP67, IP69K
- M12 I/O connectors
- LEDs indicating status and diagnostics
- Electronics galvanically separated from the field level via optocouplers
- 8 Configurable digital PNP channels, 24 VDC
- Max. 0.5A per channel
- Selection of filtering times (Input delay)
- Invertible inputs
- Simple RFID interface
- Connection of 2 BL ident® read/write heads
- Max cable length of 50 m

Type designation	BLCEN-6M12LT-2RFID-S-8XSG-P
Ident-No.	6811454
Ident-No (TUSA)	F6811454
Nominal system voltage	24 VDC
System power supply	Via auxiliary power
Voltage supply connection	2 x M12, 5-pin
Admissible range Vi	18...30VDC
Nominal current Vi	250 mA
Max. current Vi	2 A
Admissible range Vo	18...30VDC
Nominal current Vo	100 mA
Max. current Vo	4 A
Electrical isolation	The inputs and outputs of the 8XSG I/O cards are supplied via a common ground. Therefore, it is recommend not to use this module for safety or emergency stop applications.

Fieldbus transmission rate	10/100 Mbps
Adjustment transmission rate	Automatic detection
Fieldbus address range	1...92 0 (192.168.1.254) 93 (BootP) 94 (DHCP) 95 (PGM) 96 (PGM-DHCP) *Recommended for PROFINET 97...98 (manufacturer specific)
Fieldbus addressing	2 decimally coded rotary switches
Fieldbus connection technology	2 x M12 4-pole, D-coded
Protocol detection	automatic
Web server	Integrated
Service Interface	Ethernet
Vendor ID	48
Product type	12
Product code	11454

Modbus TCP	
Addressing	Static IP, BOOTP, DHCP
Supported function codes	FC1, FC2, FC3, FC4, FC5, FC6, FC15, FC16, FC23
Number of TCP connections	6
Input Data Size	max. 15 register
Input register start address	0 (0x0000 hex)
Output Data Size	max. 13 register
Output register start address	2048 (0x0800 hex)

BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P

EtherNet/IP™

Addressing	acc. to EtherNet/IP™ specification
Device Level Ring (DLR)	supported
Number of CIP connections	6
Input Assembly Instance	103
Input Data Size	16 INT
Output Assembly Instance	104
Output Data Size	13 INT
Configuration Assembly Instance	106
Configuration Size	0
Comm Format	Data - INT

PROFINET

Addressing	DCP
Conformance class	B (RT)
MinCycleTime	1 ms
Diagnostics	acc. to PROFINET alarm handling
Topology detection	supported
Automatic addressing	supported
Media Redundancy Protocol (MRP)	supported
Input Data Size	max. 26 BYTE
Output Data Size	max. 26 BYTE

Digital inputs

	From 8XSG
Input type	PNP
Type of input diagnostics	Group diagnostics
Sensor supply (V_{SENS})	24 VDC
Low level signal voltage	4.5 V
Low level signal voltage	< 4.5 VDC
High level signal voltage	7...30 VDC
Low level signal current	< 1.5 mA
High level signal current	2.1...3.7 mA
Input delay	(configurable) 0.25 or 2.5 ms

Digital outputs

	From 8XSG
Output type	PNP
Sensor supply (V_{SENS})	24 VDC
Output current per channel	0.5 A
Output voltage	24 VDC
Output delay	3 ms
Load type	resistive, inductive, lamp load
Load resistance, resistive	> 48 Ω
Load resistance, inductive	< 1.2 H
Lamp load	< 3 W
Switching frequency, resistive	< 200 Hz
Switching frequency, inductive	< 2 Hz
Switching frequency, lamp load	< 20 Hz
Short-circuit protection	yes

Technology

Signal type	Simple RFID interface
Number of channels	2
Sensor supply	0.5 A per channel, short-circuit proof
Simultaneity factor	1
Transmission rate	115.2 kbps
Cable length	50 m
Electrical isolation	isolation of electronics and field level via optocouplers

**BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P**

Dimensions	168 x 71 x 32.5 mm
Mounting	2 × 5.4 mm diameter holes, 1.7 Nm torque
Weight	600 ± 20 g
Housing material	Glass-filled nylon, nickel plated brass connectors
Housing color	Black
Window material	Lexan
Material screw	Nickel-plated brass
Material label	Polyester with polycarbonate overlay
Ground tab material	Nickel plated brass
Protection class	IP67 IP69K
Operating temperature	-40...+70 °C
Storage temperature	-40...+85 °C
Relative humidity	15 to 95% (non-condensing)
Vibration test	according to IEC 61131-2
Extended vibration resistance - up to 20 g (at 10 up to 150 Hz)	For mounting on base plate or machinery
Shock test	according to IEC 61131-2
Electro-magnetic compatibility	according to IEC 61131-2
MTTF	97 years
MTTF note	acc. to SN 29500 (Ed. 99) 20 °C
Approvals and certificates	CE, cULus, Class I Div.2

BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P

Pinning and wiring diagram

	<p>Ethernet Fieldbus cable (IP67 example): RSSD RSSD 441-2M ID number U-02482 or RSSD-RSSD-441-2M/S2174 ID number 6914218</p>	<p>Pin Assignment (M12, D-code)</p> <p>1 = TD + 2 = RD + 3 = TD - 4 = RD -</p>
	<p>Slot 1: RFID Channels Extension cable (example): RK 4.5T-2-RS 4.5T/S2501 ident-no. U3-01243 or RK4.5T-2-RS4.5T/S2500 ident-no. 6699200</p>	<p>.../S2500 Connectors</p> <p>1 = BN (+) 2 = BK (Data) 3 = BU (GND) 4 = WH (Data) 5 = shield</p> <p>.../S2501 Connectors</p> <p>1 = BN (+) 2 = WH (Data) 3 = BU (GND) 4 = BK (Data) 5 = shield</p>
	<p>Slot 2: Digital Inputs and Outputs Extension cable (example): RK 4.4T-2-RS 4.4T ident-no. U2445 or RKC4.4T-2-RSC4.4T/TEL ident-no. 6625208</p>	<p>Pin Assignment</p> <p>1 = VSENS 2 = Signal B 3 = GND 4 = Signal A 5 = PE</p>
	<p>Auxiliary Power Extension cable (example): RKC 4.4T-2-RSC 4.4T ident-no. U5264 or RKC4.4T-2-RSC4.4T/TEL ident-no. 6625208</p>	<p>Pin Assignment</p> <p>1 = Vi 2 = Vo 3 = GND 4 = GND 5 = PE</p>

BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P

Station LED status

LED	Color	Status	Description
IOs		OFF	No power
	RED	ON	Low power or station error
	RED	FLASHING (1 Hz)	I/O module configuration error
	RED	FLASHING (4 Hz)	No I/O module bus communication
	GREEN	ON	Station ok
	GREEN	FLASHING	Force mode active
BUS		OFF	Power Off
	GREEN	ON	Connected to Master
	GREEN	FLASHING	Ready
	GREEN	FLASHING 3x (1Hz)	ARGEE Running
	RED	ON	Error
	RED	FLASHING	WINK
	YELLOW	ON	DHCP/BOOTP Search
LNK/ACT		OFF	No Link
	GREEN	ON	Link
	GREEN	FLASHING	Traffic
	YELLOW	ON	100 Mbit Linked

I/O LED status slot 1

LED	Color	Status	Description
D1 *		OFF	No diagnostics active
	RED	ON	Station error/ module bus communication failure
	RED	FLASHING (0.5Hz)	Diagnostics active (Slot 1)
RW0 / RW1		OFF	No tag present, no diagnostics active
	GREEN	ON	Tag present
	GREEN	FLASHING (2 Hz)	Data communication from / to tag active
	RED	ON	Error in the R/W head
	RED	FLASHING (2 Hz)	Short circuit in the transceiver supply

* D1 LED also indicates gateway diagnostics

I/O LED status slot 2

LED	Color	Status	Description
D2 *		OFF	No diagnostics active
	RED	ON	Station error/ module bus communication failure
	RED	FLASHING (0.5Hz)	Diagnostics active (Slot 2)
XSG channels 2 ₀ ...2 ₇		OFF	Channel status x = "0" (OFF), no diagnostics active
	GREEN	ON	Channel status x = "1" (ON)
	RED	ON	Short-circuit at output

* D2 LED also indicates gateway diagnostics

BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P

Process Data Mapping of Each Protocol

EtherNet/IP™ I/O & Diagnostics Data Mapping

INPUT	BYTE	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
RFID 1 ₀	0	Done	Busy	Error	Trans. Conn.	Trans. On	TP	TFR	-
	1	Error Cat. (Category Code)							
	2	Error Desc. (Description Code)							
	3	-	-	-	-	-	-	-	-
	4...11	Read Data (8 Byte)							
RFID 1 ₁	12	Done	Busy	Error	Trans. Conn.	Trans. On	TP	TFR	-
	13	Error Cat. (Category Code)							
	14	Error Desc. (Description Code)							
	15	-	-	-	-	-	-	-	-
	16...23	Read Data (8 Byte)							
	24	DI 2 ₇	DI 2 ₆	DI 2 ₅	DI 2 ₄	DI 2 ₃	DI 2 ₂	DI 2 ₁	DI 2 ₀
	25	-	-	-	-	-	-	-	-
Diagnostics	26	Module number reporting diagnostic data							
	27	Replace Station	-	Diagnostics Active	-	-	-	-	-
Slot 1 (ref. Byte 26)	28	-	-	-	-	-	RFID 1 ₀ Trans. PS Off	-	-
	29	-	-	-	-	RFID 1 ₀ Trans. PS Error	-	-	RFID 1 ₀ Trans. Hardware Error
	30	-	-	-	-	-	RFID 1 ₁ Trans. PS Off	-	-
	31	-	-	-	-	RFID 1 ₁ Trans. PS Error	-	-	RFID 1 ₁ Trans. Hardware Error
OUTPUT	BYTE	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
RFID 1 ₀	0	Transceiver	Next	Tag ID	Read	Write	Tag Info.	Trans. Info.	Reset
	1	-	-	-	-	-	Byte Count 2	Byte Count 1	Byte Count 0
	2	Address High Byte (MSB)							
	3	Address Low Byte (LSB)							
	4...11	Write Data (8 Byte)							
RFID 1 ₁	12	Transceiver	Next	Tag ID	Read	Write	Tag Info.	Trans. Info.	Reset
	13	-	-	-	-	-	Byte Count 2	Byte Count 1	Byte Count 0
	14	Address High Byte (MSB)							
	15	Address Low Byte (LSB)							
	16...23	Write Data (8 Byte)							
	24	DO 2 ₇	DO 2 ₆	DO 2 ₅	DO 2 ₄	DO 2 ₃	DO 2 ₂	DO 2 ₁	DO 2 ₀
	25	-	-	-	-	-	-	-	-

Modbus® TCP Register Mapping

	REG	Bit 15	Bit 14	Bit 13	Bit 12	Bit 11	Bit 10	Bit 9	Bit 8	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
Inputs (RO)	0x0000	Error Cat. (Category Code)								Done	Busy	Error	Trans. Conn.	Trans. On	TP	TFR	-
	0x0001	Error Desc. (Description Code)															
	0x0002 ... 0x0005	Read Data (4 Words)															
	0x0006	Error Cat. (Category Code)								Done	Busy	Error	Trans. Conn.	Trans. On	TP	TFR	-
	0x0007	Error Desc. (Description Code)															
	0x0008 ... 0x000B	Read Data (4 Words)															
	0x000C	-	-	-	-	-	-	-	-	-	DI 2 ₇	DI 2 ₆	DI 2 ₅	DI 2 ₄	DI 2 ₃	DI 2 ₂	DI 2 ₁
Status (RO)	0x000D	-	FCE	-	-	CFG	COM	VI low	-	VO low	-	-	-	-	-	-	DIA
Diag. (RO)	0x000E	-	-	-	-	-	-	-	-	-	-	-	-	-	-	S2 DIA	S1 DIA
Outputs (RW)	0x0800	-	-	-	-	-	Byte CNT 2	Byte CNT 1	Byte CNT 0	Trans.	Next	Tag ID	Read	Write	Tag Info.	Trans. Info.	Reset
	0x0801	Address															
	0x0802 ... 0x0805	Write Data (4 Words)															
	0x0805																

BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P


	0x0806	-	-	-	-	-	Byte CNT 2	Byte CNT 1	Byte CNT 0	Trans.	Next	Tag ID	Read	Write	Tag In- fo.	Trans. Info.	Reset
	0x0807	Address															
	0x0808 ... 0x080B	Write Data (4 Words)															
	0x080C	-	-	-	-	-	-	-	-	DO 2 ₇	DO 2 ₆	DO 2 ₅	DO 2 ₄	DO 2 ₃	DO 2 ₂	DO 2 ₁	DO 2 ₀
I/O Diag. (RO)	0xA000	-	-	-	-	PS RFID 1 ₀	-	-	HW RFID 1 ₀	-	-	-	-	-	SCO RFID 1 ₀	-	-
	0xA001	-	-	-	-	PS RFID 1 ₁	-	-	HW RFID 1 ₁	-	-	-	-	-	SCO RFID 1 ₁	-	-
	0xA002	SCDO 2 ₇	SCDO 2 ₆	SCDO 2 ₅	SCDO 2 ₄	SCDO 2 ₃	SCDO 2 ₂	SCDO 2 ₁	SCDO 2 ₀	SCDI 2 ₇	SCDI 2 ₆	SCDI 2 ₅	SCDI 2 ₄	SCDI 2 ₃	SCDI 2 ₂	SCDI 2 ₁	SCDI 2 ₀

PROFINET® Process Data

	BYTE	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	
Inputs	0	RFID 1 ₀ Done	RFID 1 ₀ Busy	RFID 1 ₀ Error	RFID 1 ₀ Trans. Conn.	RFID 1 ₀ Trans. On	RFID 1 ₀ TP	RFID 1 ₀ TFR	-	
	1	RFID 1 ₀ Error Cat. (Category Code)								
	2	RFID 1 ₀ Error Desc. (Description Code)								
	3	-	-	-	-	-	-	-	-	
	4...11	RFID 1 ₀ Read Data (8 Byte)								
	12	RFID 1 ₁ Done	RFID 1 ₁ Busy	RFID 1 ₁ Error	RFID 1 ₁ Trans. Conn	RFID 1 ₁ Trans. On	RFID 1 ₁ TP	RFID 1 ₁ TFR	-	
	13	RFID 1 ₁ Error Cat. (Category Code)								
	14	RFID 1 ₁ Error Desc. (Description Code)								
	15	-	-	-	-	-	-	-	-	
	16...23	RFID 1 ₁ Read Data (8 Byte)								
Outputs	0	RFID 1 ₀ Transceiver	RFID 1 ₀ Next	RFID 1 ₀ Tag ID	RFID 1 ₀ Read	RFID 1 ₀ Write	RFID 1 ₀ Tag Info.	RFID 1 ₀ Trans. Info.	RFID 1 ₀ Reset	
	1	-	-	-	-	-	RFID 1 ₀ Byte Count 2	RFID 1 ₀ Byte Count 1	RFID 1 ₀ Byte Count 0	
	2	RFID 1 ₀ Address High Byte (MSB)								
	3	RFID 1 ₀ Address Low Byte (LSB)								
	4...11	RFID 1 ₀ Write Data (8 Byte)								
	12	RFID 1 ₁ Transceiver	RFID 1 ₁ Next	RFID 1 ₁ Tag ID	RFID 1 ₁ Read	RFID 1 ₁ Write	RFID 1 ₁ Tag Info.	RFID 1 ₁ Trans. Info.	RFID 1 ₁ Reset	
	13	-	-	-	-	-	RFID 1 ₁ Byte Count 2	RFID 1 ₁ Byte Count 1	RFID 1 ₁ Byte Count 0	
	14	RFID 1 ₁ Address High Byte (MSB)								
	15	RFID 1 ₁ Address Low Byte (LSB)								
	16...23	RFID 1 ₁ Write Data (8 Byte)								
24	DO 2 ₇	DO 2 ₆	DO 2 ₅	DO 2 ₄	DO 2 ₃	DO 2 ₂	DO 2 ₁	DO 2 ₀		
25	-	-	-	-	-	-	-	-		

**BL compact™ multiprotocol fieldbus station for Industrial Ethernet
Interface for Connection of 2 BL ident Read/Write Heads (HF/UHF) and 8
Configurable Digital PNP Channels
BLCEN-6M12LT-2RFID-S-8XSG-P**

Accessories

Type code	Ident-No.	Description	
LOCK-EURO-C	A0885	Locking guard for straight eurofast™ C-body connectors (RKC, RKCV, RSC, RSCV) in a Class I, Division 2 installations	
LOCK-EURO-C (10/BAG)	A0886	Locking guard for straight eurofast™ C-body connectors (RKC, RKCV, RSC, RSCV) in a Class I, Division 2 installations	